

# Attestation

## BREEAM International

On 20 August 2020, Eurofins Product Testing A/S received a sample of coating with the product name:

### COLOURS FOR LIFE paint No. 516 / 517

supplied by

### AURO Pflanzenchemie AG

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the testing standards specified in Indoor Air Comfort GOLD version 6.0: EN 16516, EN 16402 ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 and ISO 11890-2, respectively (See test report no. 392-2020-00356601\_A\_EN and 392-2020-00356602\_XI\_EN).

**Evaluation of the emission and content test results according to the exemplary level emission criteria (table 18) and VOC content criteria (table 19) of: BREEAM Int.: Hea 02 Indoor air quality:**


- Carcinogenic substances were not detectable after 28 days ( $< 0.001 \text{ mg/m}^3$ ).
- The sum of VOC ("TVOC") after 28 days was below the limit of  $0.3 \text{ mg/m}^3$ .
- The sum of SVOC after 28 day was below the limit of  $0.1 \text{ mg/m}^3$ .
- Formaldehyde after 28 days was below the limit of  $0.01 \text{ mg/m}^3$ .
- VOC content of less than  $10 \text{ g/L}$ .

**The tested product complies with the requirements of BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor air quality (version SD233 issue 2.0 of July 2017).**

15 October



Pernille Krintel  
Analytical Service Manager



Rasmus Stengaard Christensen  
Analytical Service Manager, MSc in Chemistry