

# Confirmation

## BREEAM<sup>®</sup> NOR 2016

On 20 August 2020, Eurofins Product Testing A/S received a sample of a paint with the product name:

**COLORS FOR LIFE paint No. 516/517**

supplied by

**AURO Pflanzenchemie AG**

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000-3 -6 -9 -11, EN 16516 and ISO 11890-2 in the latest versions (See test report no. 392-2020-00356601\_A\_EN and 392-2020-00356602\_XI\_EN).

**The test results of the tested paint indicate that the product qualifies for BREEAM-NOR New Construction 2016 v1.2 (2019) specifications on VOC emissions and VOC content by complying with:**

**BREEAM NOR 2016 requirements on "Volatile Organic Compounds" in Hea 02 criteria for paints and varnishes**

**VOC emissions specifications:**

- TVOC was below the limit of 200 µg/(m<sup>2</sup>\*h) after 28 days
- Formaldehyde was below the limit of 24 µg/(m<sup>2</sup>\*h) after 3 days
- Formaldehyde was below the limit of 50 µg/(m<sup>2</sup>\*h) after 28 days
- Carcinogenic substances was below the limit of 5 µg/(m<sup>2</sup>\*h) after 28 days

**VOC content specifications:**

- the requirements of the EU Decopaint Directive 2004/42/CE

2 March 2021



Janne Rothmann Norup  
Analytical Service Manager